

**City of Overland Park**

**Traffic Services Division**

**Equipment Submittal Memorandum**



---

August 1, 2003

TO:      Brian Shields, P.E., City Traffic Engineer  
          Guy Alon, P.E., Civil Engineer II  
          Victor Godinez, Sr. Traffic Engineering Technician  
          Lori Mansfield, Traffic Engineering Technician  
          Dave Bergner, Superintendent of Operations  
          Buck Taylor, Traffic Signal Specialist II  
          John LaPlante, Traffic Signal Specialist II  
          Jay Meador, PW Maintenance Supervisor  
          Ron Hyland, Transportation Project Inspector I  
          Carey Seaborn, Traffic Control Technician, Sr.  
          Margaret Douglas, Civil Engineer I

Ralph Lewis, P.E., Assistant City Traffic Engineer  
TBD, Traffic Engineering Technician  
Larry Killer, Sr. Traffic Engineering Technician  
Michael Hay, Traffic Engineering Technician  
Mike Newman, Transportation Project Inspector II  
Thuan Tran, Traffic Signal Specialist II  
Liz Tidd, Inventory Control Clerk  
Ron Ditmars, PW Maintenance Supervisor  
Jeni Fitzpatrick, Engineering Technician II  
Gene Stevenson, Sr. Street Lighting Inspector  
Ron DeSota, Transportation Project Inspector I

Please forward this information on to other interested parties that are not listed above.

FROM: Bruce Wacker, Supervisory Civil Engineer

RE: Encore Electrical Pole Cable #10 AWG

REMARKS:

Encore Wire has been approved for use on City of Overland Park street lighting projects for the #10 AWG USE cable.

Typically, I have not approved any cable if it did not have the name of the manufacturer imprinted on the jacket. However, it was brought to my attention that a previous approved manufacturer did not have their name on the cable. However, they print their UL file or E-number on the cable. I have a web page that I can check to verify the manufacturer of the cable. This meets the requirement to be able to track down the manufacturer in the future.

Therefore, as long as an UL E-number is listed on the cable jacket, I will approve the cable.

Encore's UL file or E-number is:  
E-174428