

1-877-350-7568

CONSTRUCTION FABRICS & SUPPLY

1603 James P. Rogers Drive
Valdosta Ga. 31601
(229) 244-0004 / FAX (229) 244-9932
1-800-686-1862

DATE: 12-15-05
TO: GORDON ENERGY
FROM: SCOTT MILLER
PHONE: 913-764-6229
FAX: 913-764-8198

CFS5009 SILT FENCE

MATERIAL:	POLYPROPYLENE	
GRAB TENSILE	ASTM-D4632	124X124 LBS.
MULLEN BURST	ASTM-D3786	300 PSI
GRAB ELONGATION	ASTM-D4632	20/15%
PUNCTURE	ASTM-D4833	7466 LBS.
TRAPEZOID TEAR	ASTM-D4533	66 LBS
A.O.S.	ASTM-D4751	#30 US SIEVE
FLOW RATE	ASTM-D4491	10 GAL/MIN/FT ²
PERMITTIVITY	ASTM-D4491	.05
UV RESISTENCE	ASTM-D4355	80%/500 HOURS

+ FREIGHT

Meets AASHTO-M288 Standards.

#8086	3X1500	135.00 PER ROLL
2002	1.5X1.5X48 STAKES	.66 PER EACH

MODOT IS 5' ON CENTER

KDOT IS 4' ON CENTER

ENGINEERING DIVISION	
PUBLIC WORKS DEPARTMENT City of Overland Park, Kansas	
Date	3-10-06
Reviewed By	JSA
<input checked="" type="checkbox"/> APPROVED	<input type="checkbox"/> APPROVED AS NOTED
Project	