



Note: These clearances are per 2002 NESC Rule 234B. Consult Standards Engineering for exceptions

If the nearest powerline is closer than 10' away from the proposed pole location, KCP&L will need to sleeve the line during pole installation. They will invoice the City unless we call it out in the plans for the contractor to pay it.

MINIMUM CLEARANCE OF WIRES FROM STREET LIGHT STRUCTURE & LUMINAIRE

DWG REV: 11/8/05 DWG: 130.1-12



DISTRIBUTION CONSTRUCTION STANDARDS

CODE REQUIREMENTS
General

Issued: 1/1/2008
130.1-12