

620 - ASPHALT SIDEWALK CONSTRUCTION

620.1 DESCRIPTION

At the locations shown on the plans the Contractor shall construct an asphalt sidewalk. The asphaltic mix to be used for this construction shall conform to the requirements for mix designation "Asphaltic Concrete Intermediate Course" as specified in specification section "OVERLAND PARK SUPERPAVE ASPHALTIC CONCRETE SURFACE AND INTERMEDIATE COURSE".

620.2 CONSTRUCTION REQUIREMENTS

a. Subgrade Preparation

The subgrade shall be uniformly compacted and evenly graded to the required subgrade elevation. All loose or extraneous material shall be removed from the subgrade and soft spots shall be uniformly recompacted prior to placement of asphalt. Asphalt sidewalks shall be constructed on a prepared subgrade, compacted to Type AA MR-3-3 standards for a minimum depth of 6 inches unless otherwise indicated on the plans. The Contractor shall have available adequate hand or mechanical compaction equipment to accomplish the compaction as set forth in these specifications.

b. Dimensions

The width of the asphalt sidewalk shall be as indicated on the plans, and the thickness shall be 4 inches unless otherwise indicated on the plans.

c. Finish

The Contractor shall provide adequate paving equipment and tools to produce quality workmanship in placing and compacting asphalt. Compaction shall be as specified in specification section "OVERLAND PARK SUPERPAVE ASPHALTIC CONCRETE SURFACE AND INTERMEDIATE COURSE".

620.3 MEASUREMENT AND PAYMENT

The Engineer will measure the asphalt sidewalk of specified thickness by the ton.

Payment for "Asphalt Sidewalk (Intermediate Course)" at the contract unit price bid is full compensation for the specified work.