

711 - REINFORCING STEEL

711.1 DESCRIPTION

All fabrication and placement of reinforcing steel shall be in conformance with Section 711 of the Standard Specifications. All reinforcing shall be as shown on the drawings and shall be held in place and positioned by pins or bar chairs or other approved devices or methods.

711.2 MATERIALS

Reinforcement shall be new billet ASTM A615 Grade 60 for KCMMB 5K concrete construction, or as shown on the plans. Reinforcing shall be new billet ASTM A615 Grade 40 for all other construction, or as shown on the plans.

711.3 CONSTRUCTION REQUIREMENTS

Reinforcing steel shall not be inserted into fresh concrete.

711.4 MEASUREMENT AND PAYMENT

For bridge construction, the Engineer will measure the reinforcing steel of the specified grade and coating by the pound.

Payment for "Reinforcing Steel" at the contract unit price bid is full compensation for the specified work. Reinforcing steel used in structures other than bridges shall be considered subsidiary to other bid items.