

Traffic Services Division

Material Submittal Memorandum

Sept 9, 2022

TO:

Brian Shields	City Traffic Engineer	Josh Welge	Mgr. Maintenance Operations
Bruce Wacker	Supervisory Civil Engineer	Greg Scharff	Public Works Superintendent
Shawn Gotfredson	Supervisory Civil Engineer	Sean Ruis	PW Maintenance Supervisor
Andrew Morrow	Civil Engineer, Sr.	Garrett Rosenbaum	Maintenance Crew Leader
Vacant	Civil Engineer	John Hightower	Traffic Signal Specialist
Brian Geiger	Civil Engineer, Sr.	Tony Cook	Traffic Signal Specialist
Larry Killer	Traffic Engineering Tech, Sr.	Cassandra Wasser	Traffic Signal Specialist
Daniel Hunt	Traffic Engineering Tech, II	Open	Traffic Signal Specialist
Janet Luessenheide	Traffic Engineering Tech, Sr.	Dylan Weber	Traffic Signal Technician
Israel Barradas	Transportation Project Inspector, Sr	Rob Allen	Street Lighting Technician
Dennis Torrence	Transportation Project Inspector, Sr	Aron Espinosa	Street Lighting Technician
Michael Petty	Transportation Project Inspector II	Gary Jacobs	Street Lighting Technician
Tony Meyers	Manager of Engineering Services	Vacant	Street Lighting Technician
Brandon Melius	Construction Inspector, Sr.	Anthony Gutierrez	Traffic Control Technician
Mark Zarda	Construction Inspector, Sr.	Wayne Honn	Traffic Control Technician
Paul West	Construction Inspector I	Vacant	Traffic Control Technician
Jesse Rhynerson	Construction Inspector II	Jeff Smiley	Inventory Control Clerk
Pam Fortun	Supervisory Civil Engineer		
Megan Viviano	Civil Engineer II		
Anne Hays	Civil Engineer II		
Jane Manis	Civil Engineer II		

Please forward this information on to other interested parties that are not listed above.

FROM: Brian Geiger, Senior Traffic Engineer

RE: EV Station Electrical Meter Control Center

REMARKS:

The Milbank Electrical Meter Control Center has been approved for use on Level 2 EV Station projects.
~~The catalog number is CP3B54C1ERAOSP1.~~
 The single 400 amp meter supports up to eight 60 amp tandem circuit breakers for individual EV Charging Station ports.

Update Sept. 29, 2025 – Brian Geiger

CP3BR5424110AO01 is the new part number for CP3B54C1ERAOSP1. This is a part number change only, necessitated by Milbank's new ERP system and updated part numbering logic. The only difference in the components is the surge protector. The new unit (CP3BR5424110AO01) has a Citel M50-120T-B surge protector instead of the Mersen M50-120T-B due to cost and availability.