




ITEM:
 CATALOG NUMBER
 PRMS-H3-CHM
 06A-1814

FINISH: POLYESTER POWDER COAT.
 PAAL COLOR: BLK

TO MATCH:

PROVIDE A SAMPLE COLOR CHIP

LAMPING ED-17

LAMP TYPE HPS

SOCKET PULSE RATED MEDIUM

WATTAGE 150

VOLTAGE 240

ALL BALLAST ARE HPS CON-
 STANT WATTAGE, 30 DEGREE
 STARTING. ALL SOCKETS ARE
 PORCELAIN, PULSE RATED 4KVA.

ANCHOR BOLTS
 QTY

SIZE

BOLT CIRCLE

PROJECTION

FS1FS2 OPTIONS.
 FUSE HOLDERS ONLY
 FUSES BY OTHERS

LEVELING NUTS AND WASHERS
 MUST BE INSTALLED UNDER ALL
 BASES

ONE APPROVED DRAWING
 MUST BE RETURNED TO A.A.L.
 BEFORE THIS PRODUCT CAN BE
 FABRICATED.

WARNING: THIS FIXTURE MUST
 BE GROUNDED IN ACCORDANCE
 WITH LOCAL CODES OR THE
 NATIONAL ELECTRICAL CODE.
 FAILURE TO DO SO MAY RESULT
 IN SERIOUS PERSONAL INJURY

SOLD TO CITY OF OVERLAND PO# 260058 JOB NAME CITY OF OVERLAND PARK STREET LTG.

ARCHITECTURAL
 AREA
 LIGHTING
 9/26/06
 80% TO APPROVAL
 REQUIRED

14249 Artesia Blvd. P.O. Box 1869
 La Mirada CA 90638-1869
 (714) 994-2700 fax (714) 994-0522

Architectural Area Lighting Inc.
 Reserves The Right To Change
 Manufacturing Processes Without
 Notice

06A-1814

DATE 09-23-06 DRWN A.F.M.

DATE APPROVD

DATE REV.