

ITEM NO.	DESCRIPTION	QUANTITY
		A B C D E
1.	TOP PLATE, 1-1/4" X 15" X 8" - 14-1/2"	1
2.	PIPE SHAFT, 8" SCH 20 X 60"	1
3.	HELIX, STL, 3/8" X 14" X 1-1/4"	1
4.	STINGER, RBAR, 1-1/4" X 12"	1
5.	STUD, TAP END, 1 X 4	4
6.	WASHER, PLAIN, 1"	4
7.	NUT, HEX, 1"	4



NOTES

1. MATERIAL : SHAFT - ASTM A252
TOP PLATE - ASTM A36
HELIX - ASTM A36
PILOT POINT - ASTM A575
STUD - AISI C1045
2. HOT DIP GALV. PER ASTM A153, AFTER FABRICATION.
3. ANCHOR SHALL BE SHIPPED WITH HARDWARE BAGGED AND SECURED TO PIPE SHAFT.
4. ANCHOR IS DESIGNED TO CONFORM TO THE CITY OF OVERLAND PARK SPECIFICATIONS FOR ANCHORS WITH A MAXIMUM TORQUE RATING OF 20,000 FT-LBS.

CATALOG NO.	PART
D-1202-0032	A

REV.	DATE	DESCRIPTION
D	06/24/98	SCALE NONE
C		CHECKED SCG
B		APPROVED S.GARTON
A		DRAWN K.OSVAIH

ALL UNTOLERANCED DIMENSIONS ARE FOR REFERENCE PURPOSES AND HAVE BEEN PREVIOUSLY DIMENSIONED AND TOLERANCED ON LOWER LEVEL DRAWINGS.

SHAFT, ASTM A252 WAS A501	24 JUN 98	ALL INFORMATION CONTAINED IN THIS DISCLOSURE WHETHER PATENTABLE OR OTHERWISE COMPRISES PROPRIETARY INFORMATION OF DIXIE ELECTRICAL MANUFACTURING CO AND ITS UNAUTHORIZED USE OR PUBLICATION WITHOUT THE EXPRESS CONSENT OF DIXIE ELECTRICAL MANUFACTURING CO IS STRICTLY PROHIBITED.
CHGD HELIX TO A36	20 SEP 95	
ADDED STEEL STENCIL	1-9-92	
CHANGED FROM	DATE	

DIXIE ELECTRICAL
MANUFACTURING COMPANY
P.O. BOX 170040
BIRMINGHAM, ALABAMA 35217-0040

NAME FOUNDATION ANCHOR,
8" X 60", TYPE F2
CITY OF OVERLAND PARK

DR. NO. P1070

REV. D