

City of Overland Park

Traffic Services Division

Equipment Submittal Memorandum



August 1, 2003

TO: Brian Shields, P.E., City Traffic Engineer
 Guy Alon, P.E., Civil Engineer II
 Victor Godinez, Sr. Traffic Engineering Technician
 Lori Mansfield, Traffic Engineering Technician
 Dave Bergner, Superintendent of Operations
 Buck Taylor, Traffic Signal Specialist II
 John LaPlante, Traffic Signal Specialist II
 Jay Meador, PW Maintenance Supervisor
 Ron Hyland, Transportation Project Inspector I
 Carey Seaborn, Traffic Control Technician, Sr.
 Margaret Douglas, Civil Engineer I

Ralph Lewis, P.E., Assistant City Traffic Engineer
TBD, Traffic Engineering Technician
Larry Killer, Sr. Traffic Engineering Technician
Michael Hay, Traffic Engineering Technician
Mike Newman, Transportation Project Inspector II
Thuan Tran, Traffic Signal Specialist II
Liz Tidd, Inventory Control Clerk
Ron Ditmars, PW Maintenance Supervisor
Jeni Fitzpatrick, Engineering Technician II
Gene Stevenson, Sr. Street Lighting Inspector
Ron DeSota, Transportation Project Inspector I

Please forward this information on to other interested parties that are not listed above.

FROM: Bruce Wacker, Supervisory Civil Engineer

RE: Encore Electrical Pole Cable #10 AWG

REMARKS:

Encore Wire has been approved for use on City of Overland Park street lighting projects for the #10 AWG USE cable.

Typically, I have not approved any cable if it did not have the name of the manufacturer imprinted on the jacket. However, it was brought to my attention that a previous approved manufacturer did not have their name on the cable. However, they print their UL file or E-number on the cable. I have a web page that I can check to verify the manufacturer of the cable. This meets the requirement to be able to track down the manufacturer in the future.

Therefore, as long as an UL E-number is listed on the cable jacket, I will approve the cable.

Encore's UL file or E-number is:

E-123744

This was changed 1/18/19 by BLW