

City of Overland Park

Traffic Services Division

Equipment Submittal Memorandum



September 11, 2007

TO: Brian Shields, P.E., City Traffic Engineer
 Guy Alon, I.E., Civil Engineer II
 Victor Godinez, Sr. Traffic Engineering Technician
 Lori Ferguson, Sr. Traffic Engineering Technician
 Dave Bergner, Public Works Superintendent
 Buck Taylor, Traffic Signal Specialist
 John LaPlante, Traffic Signal Specialist
 Thuan Tran, Traffic Signal Specialist
 John Hightower, Traffic Signal Specialist
 Tony Brenton, Street Lighting Technician
 Terry Cockrell, Street Lighting Technician
 Carey Seaborn, Sr. Traffic Control Technician
 Brandon Melius, Traffic Control Technician
 Carl Estep, Street Lighting Technician
 Ed Reyes, Engineering Technician II
 Peggy Sneegas, Engineering Services Administrator
 Rob Allen, Maintenance Worker

 Andrew Morrow, Civil Engineer I
 Larry Killer, Sr. Traffic Engineering Technician
 Michael Hay, Sr. Traffic Engineering Technician
 Ron Hyland, Transportation Project Inspector II
 Richard Lang, Transportation Project Inspector I
 Ron DeSota, Transportation Project Inspector, Sr
 Marvin Furgison, Inventory Control Clerk
 Ron Ditmars, PW Maintenance Supervisor
 Jay Meador, PW Maintenance Supervisor
 Todd Lohman, Street Lighting Technician
 Dennis Torrence, Maintenance Worker, Sr
 Gene Stevenson, Construction Inspector II
 Jerry Rogers, Sr. Traffic Control Technician
 Israel Barradas, Traffic Control Technician
 Tim Morgan, Maintenance Worker, Sr
 Jim Cannon, Construction Inspector II

Please forward this information on to other interested parties that are not listed above.

FROM: Bruce Wacker, Supervisory Civil Engineer

RE: NSI Insutries Polaris Blue Submersible Connectors

REMARKS:

NSI Insutries Polaris Blue Submersible Connectors have been approved for use in the City of Overland Park for street lighting splices within service and junction boxes. They are submersible and do not require taping. The correct product shall be used for the appropriate number of cables requiring to be spliced. e.g. A three port connector shall not be approved for use in splicing two cables together.

The product numbers are:

ITW-4 - #4 two port
IPLW4-3 - #4 three port
IPLW4-4 - #4 four port