

**Traffic Services Division**

**Equipment Submittal Memorandum**

---

**April 12, 2010**

**TO:** Brian Shields, P.E., City Traffic Engineer  
Guy Alon, I.E., Civil Engineer, Sr.  
Victor Godinez, Sr. Traffic Engineering Technician  
Trevor Leikam, Traffic Engineering Technician  
Dave Bergner, Public Works Superintendent  
Buck Taylor, Traffic Signal Specialist  
Carl Estep, Traffic Signal Specialist  
Thuan Tran, Traffic Signal Specialist  
John Hightower, Traffic Signal Specialist  
Tony Brenton, Street Lighting Technician  
Terry Cockrell, Street Lighting Technician  
Carey Seaborn, Sr. Traffic Control Technician  
Dennis Torrence, Traffic Control Technician  
Justin Tate, Street Lighting Technician  
Ed Reyes, Engineering Technician II  
Peggy Sneegas, Engineering Services Administrator

Andrew Morrow, Civil Engineer I  
Larry Killer, Sr. Traffic Engineering Technician  
David Miller, Supervisory Civil Engineer  
Ron Hyland, Transportation Project Inspector II  
Kenneth Boone, Construction Inspector II  
Ron DeSota, Transportation Project Inspector, Sr  
Marvin Furgison, Inventory Control Clerk  
Ron Ditmars, PW Maintenance Supervisor  
Jay Meador, PW Maintenance Supervisor  
Tim Morgan, Street Lighting Technician  
Jordan Dillard, Maintenance Worker, Sr  
Brandon Melius, Construction Inspector II  
Jerry Rogers, Sr. Traffic Control Technician  
Israel Barradas, Traffic Control Technician  
Jim Cannon, Construction Inspector, Sr  
Rob Allen, Maintenance Worker

Please forward this information on to other interested parties that are not listed above.

**FROM:** Bruce Wacker, Assistant City Traffic Engineer

**RE:** Clary Battery Backup / UPS unit for CNG Generator installations

**REMARKS:**

The Clary UPS unit has been approved for use with the installation of CNG generator installations. The part numbers are as follows:

SP 1250-PD-R-48 – Uninterruptible Traffic System with Integrated PIM and Programmable Display **Changed to “R” instead of “N” to designate rackmount 9/26/13 BLW**  
SPO-09A2 – SNMP Adapter with cables manual and software  
SPD-302C – Bypass Switch  
100-16136 – 48 VDC Battery Generator Interface  
104-16163-60 – 48 Volt Dual String Battery Cable  
OP96C-41 – Batteries (set of eight)  
48-volt system