

**Traffic Services Division**

**Material Submittal Memorandum**

**June 21, 2023**

**TO:**

Brian Shields	City Traffic Engineer	Josh Welge	Mgr. Maintenance Operations
Bruce Wacker	Supervisory Civil Engineer	Greg Scharff	Public Works Superintendent
Shawn Gotfredson	Supervisory Civil Engineer	Sean Ruis	PW Maintenance Supervisor
Andrew Morrow	Civil Engineer, Sr.	Garrett Rosenbaum	Maintenance Crew Leader
Vacant	Civil Engineer	John Hightower	Traffic Signal Specialist
Brian Geiger	Civil Engineer, Sr.	Tony Cook	Traffic Signal Specialist
Open	Traffic Engineering Tech, Sr.	Cassandra Wasser	Traffic Signal Specialist
Daniel Hunt	Traffic Engineering Tech, II	Open	Traffic Signal Specialist
Janet Luessenheide	Traffic Engineering Tech, Sr.	Dylan Weber	Traffic Signal Technician
Israel Barradas	Transportation Project Inspector, Sr	Rob Allen	Street Lighting Technician
Open	Transportation Project Inspector, Sr	Aron Espinosa	Street Lighting Technician
Michael Petty	Transportation Project Inspector, Sr	Gary Jacobs	Street Lighting Technician
Tony Meyers	Manager of Engineering Services	Vacant	Street Lighting Technician
Brandon Melius	Construction Inspector, Sr.	Anthony Gutierrez	Traffic Control Technician
Mark Zarda	Construction Inspector, Sr.	Open	Traffic Control Technician
Paul West	Construction Inspector I	Vacant	Traffic Control Technician
Jesse Rhynerson	Construction Inspector II	Jeff Smiley	Inventory Control Clerk
Pam Fortun	Supervisory Civil Engineer		
Megan Viviano	Civil Engineer II		
Anne Hays	Civil Engineer II		
Jane Manis	Civil Engineer II		

Please forward this information on to other interested parties that are not listed above.

**FROM:** Brian Geiger, Senior Civil Engineer

**RE:** Custom Products Corporation Aluminum Sign Blanks

**REMARKS:**

Custom Products Corporation (CPC) Aluminum Sign Blanks have been approved for use on City of Overland Park projects.  
There are too many possible sign shapes, sizes, and thicknesses to list, so contact CPC directly for part numbers.  
The aluminum blanks are aluminum alloy grade 5052H38 and come in either the required 0.080" aluminum thickness or 0.125" aluminum thickness.